

PUNJAB STATE ELECTRICITY REGULATORY COMMISSION
SITE NO. 3, BLOCK B, SECTOR 18-A MADHYA MARG, CHANDIGARH

Petition No. 62 of 2021
Alongwith IA No. 25 of 2022
Date of Hearing: 07.02.2024
Date of Order: 12.02.2024

Petition for clarification regarding applicability of PIU tariff to Electroplating Industries and some other type of industries under Regulation 69, 70, 71 & 72 of Chapter XIII of the Conduct of Business Regulations 2005.

In the matter of: Punjab State Power Corporation Limited, The Mall, Patiala.
.....Petitioner

Commission: Sh. Viswajeet Khanna, Chairperson
Sh. Paramjeet Singh, Member

Petitioner: Ms. Harmohan Kaur, CE/ARR&TR
Sh. Harjeet Singh, ASE/TR-5
Sh. K.S Anand, ASE/No-1
Sh. Rajiv Kapur, Dy.CE/Regulations

And

Petition No. 70 of 2022

Petition for clarification regarding applicability of PIU tariff to M/s Stelco Industries Pvt. Ltd., Rampura Phul using a combination of Hardening and Tempering process under Regulation 69, 70, 71 & 72 of Chapter XIII of the Conduct of Business Regulation, 2005.

In the Matter of: Punjab State Power Corporation Limited, The Mall, Patiala
.....Petitioner


Versus

M/s Stelco Industries Pvt. Ltd, National Highway NH-7 Bathinda Road, Rampura Phul, Distt. Bathinda Punjab- 151103.

.....Respondent

PSPCL: Ms. Harmohan Kaur, CE/ARR&TR
Sh. Ajay Bansal, DY.CE
Sh. K.S Anand, ASE/No-1
Sh. Rajiv Kapur, Dy.CE/Regulation

Stelco: Ms. Neetu Singh, Advocate
Sh. Jagjeet Singh



And

**Review Petition No. 01 of 2023
Alongwith IA No. 03 of 2023 in Petition No. 38 of 2022.**

Review petition under Regulation 64 read with Regulation 69 of PSERC (Conduct of Business), Regulations 2005 praying for review of the order dated 30.11.2022 rendered by this Hon'ble Commission in the main petition.

In the Matter of: Kanin Industries Pvt. Ltd., Registered Office: Block-A, Plot No. 46, Mathura road, Mohan Cooperative Industrial Estate Ltd. New Delhi.
.....Petitioner

Versus

1. Punjab State Power Corporation Limited, PSEB Head Office, The Mall, Baradari, Patiala, Pb. 147001.
2. Chief Engineer (Commercial), PSPCL, The Mall, Patiala, Pb.
3. SE, Doraha Sub-station, PSPCL, Khanna, Pb.

.....Respondents

Kanin Industries: Ms. Neetu Singh, Advocate

PSPCL: Sh. Harmail Singh, ASE, Darshan
Sh. Naveen Bhardwaj, Advocate

ORDER:

The Petitions were taken up for hearing. PSPCL has submitted the information in compliance of the order dated 12.12.2023. PSPCL shall further submit the following information/data:


1. Category of each consumer covered under sample study i.e. whether PIU of mixed or general industry with corresponding load details along with the sanctioned contract demand of each load.
2. The 95th and 99th percentile TDD values of all the consumers are same which is not correct. PSPCL should submit the actual 95th and 99th percentile TDD values.
3. The excess TDD values over prescribed TDD limits have been incorrectly calculated. The same may be recalculated.
4. The captured harmonic data appears to be for three weeks ie. from 01.01.2024 to 21.01.2024. The data of two more weeks may be submitted. Thereafter, PSPCL is at liberty to remove the meters installed for sample study.



The above information be submitted within two weeks. PSPCL submitted information in compliance of the order dated 12.12.2023 but the same has not been shared with other parties. PSPCL shall provide the information to the other parties also (through hard and soft copy).


The petition shall be taken up for hearing on 03.04.2024 at 11.30 AM.


(Paramjeet Singh)
Member


(Viswajeet Khanna)
Chairperson

Chandigarh

Dated: 12.02.2024.

Authenticated

Sheeta Chandel
Dy. Registrar
Punjab State Electricity Regulatory Commission
Chandigarh

