

PUNJAB STATE ELECTRICITY REGULATORY COMMISSION
SITE NO. 3, BLOCK B, SECTOR 18-A MADHYA MARG, CHANDIGARH

Review Petition No. 05 of 2023
in Petition No. 74 of 2022
Date of Hearing: 28.11.2024
Date of Order: 29.11.2024

Review Petition under Regulation 64 of the Punjab State Electricity Regulatory Commission (Conduct of Business) Regulations, 2005 read with Section 181 of the Electricity Act, 2003.

AND

In the matter of: HPCL Mittal Energy Limited (HMEL) through its Special Power of Attorney/Authorized Signatory Sh. Mahesh Kumar Bhagwandas Gohil, aged 60 Years S/o Sh. Vithal Gohil, Vice President Petrochemicals, Guru Gobind Singh Refinery, Village Phulokhari, Tehsil Talwandi Sabo, District Bathinda.

....Review Petitioner

Versus

Punjab State Power Corporation Limited through its Chief Engineer/ARR &TR, PSEB Head office, The Mall Patiala.

....Respondent

Commission: Sh. Viswajeet Khanna, Chairperson
Sh. Paramjeet Singh, Member

Petitioner: Sh. Ishan Gupta, Advocate
Sh. Saurabh Kapoor
Sh. K.K Singla
Sh. Davinder Singh Chaudhary

PSPCL: Sh. Anand K Ganesan, Advocate, (through VC)
Ms. Harmohan Kaur, CE/ARR&TR, (through VC)
Sh. Sachin Kapoor, Dy.CE/TR (F), (through V.C)
Sh. Harjeet Singh, ASE/TR-5

PSTCL: Sh. Saurabh Gupta, Sr.Xen/EAS

ORDER

The Review Petition was taken up for hearing. During the hearing, the counsel for Review Petitioner pointed out that PSTCL in its reply dated 24.09.2024 has not submitted the specific reply with regard to the following points:

1. PSTCL has not considered the aspect that the Regulation 12 of Central Electricity Regulatory Commission (Rates, Charges and Terms & Conditions for use of Intervening Transmission Facilities) Regulations 2010 provides for the transmission loss of 400kV line not to be more than 0.5% for a 50 km line length.
2. PSTCL has not provided the calculation of transmission loss at 400kV voltage alongwith percentage of total power at 400kV being fed to 400 kV consumers and

percentage of total power at 400kV used for stepping down to provide power to other consumers at lower voltage starting from 220 kV and below.

3. PSTCL has not provided any comments on duty of SLDC to determine the energy loss in the transmission system.

The representative appearing for PSTCL requested for time to file its reply on the above issues. The same may be filed within two weeks with a copy to the other parties (through hard and soft copy).

The Review Petition shall be taken up for hearing on 15.01.2025 at 11.30 AM.

Sd/-
(Paramjeet Singh)
Member

Sd/-
(Viswajeet Khanna)
Chairperson

Chandigarh
Dated: 29.11.2024