

**COURT OF THE LOK PAL (OMBUDSMAN),
ELECTRICITY, PUNJAB,
PLOT NO. A-2, INDUSTRIAL AREA, PHASE-1,
S.A.S. NAGAR (MOHALI).**

**(Constituted under Sub Section (6) of Section 42 of
Electricity Act, 2003)**

**APPEAL No. 04/2025
PROCEEDINGS DATED 13.03.2025**

In the Matter of:

M/s. B.S. Steels,
Village Cheema,
Tehsil Sunam, District Sangrur.
Contract Account Number: 3008676984 (MS)
...Appellant

Versus

Addl. Superintending Engineer,
DS Division, PSPCL,
Sunam.
...Respondent

Present For:

Appellant: Er. Surinder Pal Goyal,
Appellant's Representative.

Respondent : 1- Er. Brish Bhan,
AAE, DS Division, PSPCL,
Sunam.
2- Sh. Rohit Khara, RA.

During hearing, the Appellant's Representative presented his case & arguments of both the parties were heard. The Appellant's Representative pleaded that there is a provision in the meter that if due to any reason the meter records -ve energy, then this -ve energy is added to the +ve or Import energy in

which case analytically the slowness of the meter in case of interchanging of connections of two CT's can be +/- 33.33% only. The Respondent was directed to file his reply to this before next date of hearing with a copy to the Appellant.

The next date of hearing is fixed for 24.03.2025 at 01.00 PM. Both the parties are directed to be present on the next date of hearing.

March 13, 2025
S.A.S. Nagar (Mohali).

(ANJULI CHANDRA)
Lokpal (Ombudsman)
Electricity, Punjab.